


Core FB MC Operational KPI report

June 2024



Overview of Operational KPIs



Adjustment for minimum RAM Inclusion

- KPI 1: Average maximum AMR per CNE
- KPI 2: Average maximum AMR per TSO

TSOs' adjustment after validation

- KPI 3: Share of MTUs with intervention per TSO
- KPI 4: Average IVA applied for each CNE affected by TSO intervention

Power System Impact Analysis

- KPI 5: Min & max net positions per BZ hub
- KPI 6: Virtual margins at market balance for CORE TSOs
- KPI 7: Non-Core exchanges delta flow

Non-costly Remedial Action Optimization Analysis

- KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode
- KPI 9: Most limiting CNEC per TSO (NRAO)
- KPI 10: Average variation of relative RAM before and after NRAO

Market Impact Assessment

- KPI 11: Most often presolved CNEs (top 20)
- KPI 12: Most limiting CNEs (top 20)
- KPI 13: Allocation Constraints

KPI 1: Average maximum AMR per CNE (Top 10)


KPI 2: Average maximum AMR per TSO




CNE	Average Maximum AMR (MW)	AMR as % of Fmax
[BE-BE] Y-Gramme (-Courcelles - Tergnee) 380.31 [OPP]	562.66	35.56%
[D7-D7] Y-Hanekenfaehr (-Gersteinwerk - Uentrop) UENTRO N [DIR]	487.66	8.48%
[BE-BE] Y-Courcelles (-Gramme - Tergnee) 380.31 [DIR]	482.35	30.45%
[D7-D7] Gronau - Hanekenfaehr GRONAU W [OPP]	477.46	4.80%
[D7-D2] Meppen - Y Niederlangen [OPP] [D2]	421.87	18.59%
[BE-BE] Champion - Gramme 380.32 [OPP]	405.21	1.85%
[D7-D2] Hanekenfaehr - Doerpen West [OPP] [D2]	404.76	17.78%
[D7-D7] Y-Hanekenfaehr (-Kottigerhook - Kusenhorst) MUENST [DIR]	386.38	2.28%
[D7-D7] Y-Hanekenfaehr (-Oechtel - Roxel) ROXEL O [OPP]	385.78	6.99%
[D2-D2] Doerpen West - Y Niederlangen [DIR]	376.72	16.51%

TSO	Average maximum AMR per TSO
AT	88.74
BE	567.80
CZ	264.93
D2	567.48
D4	324.07
D7	667.34
D8	603.35
FR	228.26
HR	12.50
HU	159.33

TSO	Average maximum AMR per TSO
NL	170.46
PL	68.25
RO	165.30
SI	81.46
SK	151.16





KPI 3: Share of MTUs with intervention per TSO



Total BDs

29

Total MTUs

694

MTUs without IVA

251

Share of distinct MTUs without IVA

36.2%

MTUs with IVA

443


63.8%

Share of distinct

MTUs with IVA

TSO	Share of distinct MTUs with IVA	Distinct MTUs with IVA
AT	0.58%	4
BE	0.00%	0
CZ	0.00%	0
D2	0.29%	2
D4	0.00%	0
D7	0.72%	5
D8	0.58%	4
FR	51.87%	360
HR	1.59%	11
HU	0.58%	4


TSO	Share of distinct MTUs with IVA	Distinct MTUs with IVA
NL	0.72%	5
PL	3.31%	23
RO	20.61%	143
SI	1.30%	9
SK	3.89%	27



KPI 4a: Average IVA applied for each CNE affected by TSO intervention




$$\text{avg. IVA}_{CNE} = \frac{1}{\#(CNEC, MTU)[IVA_{CNEC, MTU} > 0]} \sum_{MTU, CNEC} IVA_{CNEC, MTU}[IVA_{CNEC, MTU} > 0]$$




KPI 4b: Average relative IVA applied for each CNE affected by TSO intervention



$$\text{avg. rel. IVA}_{CNE} = \frac{1}{\#(CNEC, MTU)[IVA_{CNEC, MTU} > 0]} \sum_{MTU, CNEC} \frac{IVA_{CNEC, MTU}[IVA_{CNEC, MTU} > 0]}{F_{max_{CNEC, MTU}}[IVA_{CNEC, MTU} > 0]}$$































KPI 6a: Highest virtual margins at market balance for CORE TSOs

















































































KPI 7: Non-Core exchanges AC delta flow





KPI 7: Non-Core exchanges DC delta flow






KPI 8: NRAO – Applied Remedial Action




In the following plots, the relative time share relates to the hours labeled 'NRAO Ran and Applied RAs'.




KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode





KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode Relative Time Share of Applied PSTs in Preventive Mode






KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode Relative Time Share of Applied PSTs in Curative Mode






KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode Relative Time Share of Applied Topological RAs in Preventive Mode





KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode Relative Time Share of Applied Topological RAs in Curative Mode






KPI 9: Most limiting CNEC per TSO (NRAO)



The graph below shows the distribution of CNECs which are the most limiting from NRAO perspective, these are the CNECs with lowest relative RAM per MTU



As expected, there is redistributing of the most limiting CNECs. This is because the application of Remedial Actions does not eliminate flows but re-routes, reducing the flows on some limiting CNECs and increasing the load on others, which at the end impacts also the RAM values.


KPI 10: Average variation of relative RAM before and after NRAO



The graph shows average values of relative RAM before and after NRAO, per TSO on the most limiting CNECs from NRAO perspective. Selected CNECs before RAO are the same as after RAO, and average computed for MTUs when was used further in the process.

- Most limiting element from NRAO perspective is the one which has the lowest relative RAM per MTU
- To determine value of relative RAM, the following formula was used

$$RAM_{rel} = \left\{ egin{align*} rac{RAM_{nrao}}{\sum_{(A,B) \in neighbouring\ Core\ bidding\ zones\ pairs} |PTDF_{A
ightarrow B,nrao}|},\ if\ RAM_{nrao} \geq 0 \ RAM_{nrao},\ if\ RAM_{nrao} < 0 \end{array}
ight.$$



KPI 11: Most often presolved CNEs (top 20)



CNE &	Distinct hours CNE was presolved	Count of presolved CNECs	Avg RAM/Fmax	Min RAM/Fmax	Max RAM/Fmax	Max z2zPTDF	Max sum z2zPTDF
[HU-HU] Gonyu - Gyor [DIR]	694	1476	66.31%	48.30%	97.84%	0.3021	1.6597
[SK-SK] Gabcikovo - P.Biskupice [DIR]	693	693	81.42%	68.48%	101.52%	0.2859	1.1811
[HR-SI] 220kV Pehlin - Divaca [OPP] [HR]	693	1337	108.31%	78.61%	147.86%	0.1875	0.4633
[HU-HU] Gonyu - Gyor [OPP]	692	957	118.95%	82.11%	173.14%	0.3021	1.6597
[SI-HU] 400 kV Cirkovce - Hevitz [OPP] [SI]	689	1273	75.65%	51.49%	101.26%	0.355	1.1613
[HR-SI] 220kV Pehlin - Divaca [DIR] [HR]	689	726	62.07%	34.76%	95.72%	0.1875	0.4633
[SK-HU] Gabcikovo - Gonyu [OPP] [HU]	689	1758	86.44%	60.25%	120.20%	0.3243	1.1283
[PL-CZ] Kopanina - Liskovec [OPP] [PL]	688	851	105.72%	72.37%	139.71%	0.1457	0.5183
[SK-HU] Gabcikovo - Gonyu [DIR] [HU]	686	840	85.40%	62.12%	129.29%	0.3243	1.1283
[SI-HU] 400 kV Cirkovce - Hevitz [DIR] [SI]	686	1393	103.54%	78.72%	129.85%	0.355	1.1613
[NL-D7] Maasbracht - Oberzier SELFK WS [DIR] [D7]	683	2525	68.22%	25.98%	113.97%	0.3129	0.691
[AT-SI] Obersielach - Podlog 247 [DIR] [AT]	681	1123	62.58%	22.38%	119.89%	0.2547	0.8066
[CZ-SK] Liskovec - P. Bystrica [OPP] [CZ]	680	680	103.47%	70.27%	144.02%	0.1319	0.4804
[AT-SI] Obersielach - Podlog 247 [OPP] [AT]	678	855	114.20%	49.45%	180.94%	0.2547	0.8066
[BE-FR] Avelgem - Avelin 80 [OPP] [FR]	662	662	73.18%	51.66%	99.22%	0.4841	1.126
[AT-AT] Westtirol 1 - Westtirol 2 WTRHU41 [OPP]	660	1443	68.27%	19.90%	140.00%	0.2718	1.2247
[RO-RO] TR Rosiori 400/220 1 [DIR]	656	656	47.03%	19.00%	84.25%	0.1283	0.2399
[AT-D2] St. Peter 2 - Pleinting 258 [DIR] [AT]	651	1184	69.88%	19.85%	124.91%	0.1974	0.7473
[PL-CZ] Kopanina - Liskovec [DIR] [PL]	649	865	72.00%	41.56%	107.58%	0.1457	0.5183
[SK-SK] H.Zdana - Sucany [DIR]	624	1015	72.40%	62.55%	91.56%	0.1952	0.7626

Note 1: The shown z2zPTDF values do not correspond to the maximum zone-to-zone PTDFs according to equation 5 of the Day-ahead CCM and hence are not the ones used for the CNEC Selection. The z2zPTDFs are calculated only between neighbouring BZs. See KPI reading guide on JAO.

Note 2: RAM for Core exchanges can be higher than 100% due to the relieving effect of Fuaf: RAM_Core = CEP_target - Fuaf. So if Fuaf is very negative you can get above 100%.

KPI 12: Most limiting CNEs (top 20)




CNE	Distinct hours CNE has shadow price	Count of CNECs with shadow price	Max shadow price [€/MW]	Avg RAM/Fmax 🝦	Min RAM/Fmax	Max RAM/Fmax 🍦	Max z2zPTDF
[AT-SI] Obersielach - Podlog 247 [DIR] [AT]	407	407	1432.29	55.84%	23.48%	92.22%	0.2547
[FR-FR] Creys - Saint-Vulbas 2 [OPP]	221	221	1012.67	24.77%	19.99%	43.02%	0.143
[FR-D7] Vigy - Ensdorf VIGY2 S [DIR] [D7]	153	197	795.34	47.90%	23.46%	71.97%	0.2516
[FR-FR] Frasnes - Genissiat [OPP]	141	141	1879.82	36.06%	20.02%	58.79%	0.0917
[SK-SK] V.Dur - Levice 1 [DIR]	88	88	1560.98	38.84%	27.84%	50.24%	0.199
[BE-FR] Avelgem - Avelin 80 [OPP] [FR]	88	88	257.79	66.89%	51.66%	89.12%	0.4764
[D8-PL] Mikulowa PST1 [DIR] [PL]	71	71	489.3	51.97%	27.55%	72.18%	0.4886
[D8-D8] Vierraden - Vierraden PST441 [DIR]	46	46	632.3	49.42%	40.04%	67.97%	0.3125
[RO-RO] TR Rosiori 400/220 1 [DIR]	42	42	936.76	41.64%	23.50%	77.75%	0.1152
[NL-D7] Maasbracht - Oberzier SELFK WS [DIR] [D7]	40	47	249.9	56.31%	28.52%	97.86%	0.2797
[FR-D7] Vigy - Ensdorf VIGY1 N [DIR] [D7]	38	38	492.99	43.91%	30.10%	73.67%	0.2107
[SK-UA] V.Kapusany - Mukachevo (WPS) [DIR] [SK]	38	38	417.49	48.00%	29.96%	65.35%	0.22
[RO-HU] Arad - Sandorfalva [OPP] [RO]	30	30	333.51	48.37%	29.31%	68.17%	0.3538
[NL-NL] Zwolle-Hengelo 380 W [DIR]	29	29	291.27	49.24%	19.98%	91.69%	0.3391
[PL-PL] Krosno Iskrzynia - Rzeszow [OPP]	27	28	670.81	53.64%	33.69%	71.36%	0.3476
[RO-HU] Arad - Sandorfalva [OPP] [HU]	25	25	231.01	74.72%	55.64%	92.79%	0.39
[D8-PL] Krajnik - Vierraden 2 [OPP] [PL]	20	20	481.85	33.74%	21.65%	39.89%	0.298
[HR-RS] 400kV Ernestinovo - Mitrovica [DIR] [HR]	17	17	311.05	47.13%	40.30%	53.98%	0.2715
[CZ-D8] Hradec - Rohrsdorf 445 [OPP] [D8]	17	17	147.43	44.17%	40.49%	52.81%	0.2711
[AT-D2] St. Peter 2 - Pleinting 258 [DIR] [AT]	17	18	274.07	51.07%	19.85%	101.10%	0.1619

Note 1: The RAM values (expressed as % of Fmax) should not be interpreted as "the capacities offered by the Core TSOs to the market coupling". Indeed, since the introduction of Ext LTA inclusion Euphemia performs an optimization where it takes a portion of the FB domain and a portion of the LTA domain to maximize welfare. The RAM value shown in this KPI report correspond to the "portion of the FB domain" resulting from this optimization Example:

- RAM = 500MW
- Portion of FB Domain = 40%
- RAM offered by Core TSOs = 400mW/0.4 = 1250MW

KPI 13: Allocation Constraints - Poland





	PL AC Import [MW]	PL AC Export [MW]
Avg.	-1790.65	3526.88
Min.	-9768.00	0.00
Max.	0.00	16255.00

