


# Core FB MC Operational KPI report April 2025



### **Overview of Operational KPIs**



#### **Adjustment for minimum RAM Inclusion**

- KPI 1: Average maximum AMR per CNE
- KPI 2: Average maximum AMR per TSO

#### **TSOs' adjustment after validation**

- KPI 3: Share of MTUs with intervention per TSO
- KPI 4: Average IVA applied for each CNE affected by TSO intervention

#### **Power System Impact Analysis**

- KPI 5: Min & max net positions per BZ hub
- KPI 6: Virtual margins at market balance for CORE TSOs
- KPI 7: Non-Core exchanges delta flow

#### **Non-costly Remedial Action Optimization Analysis**

- KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode
- KPI 9: Most limiting CNEC per TSO (NRAO)
- KPI 10: Average variation of relative RAM before and after NRAO

#### **Market Impact Assessment**


- KPI 11: Most often presolved CNEs (top 20)
- KPI 12: Most limiting CNEs (top 20)
- KPI 13: Allocation Constraints

## **KPI 1: Average maximum AMR per CNE (Top 10)**

# **KPI 2: Average maximum AMR per TSO**




CNE	Avg. Max. AMR (MW)	AMR/Fmax% (MTUs with AMR > 0 MW)	AMR/Fmax% (all MTUs)
[FR-FR] Creys - Saint-Vulbas 2 [OPP]	933.24	42.63%	27.42%
[NL-BE] PST Zandvliet 4 [OPP] [BE]	906.00	56.13%	0.08%
[FR-FR] Creys - Saint-Vulbas 1 [OPP]	877.49	39.32%	39.27%
[BE-BE] Doel - Zandvliet 380.25 [OPP]	850.00	55.27%	0.08%
[NL-NL] Lelystad-Ens 380 Z [OPP]	790.34	28.52%	5.11%
[NL-NL] Lelystad-Ens 380 W [OPP]	790.34	28.52%	5.11%
[D2-D8] Helmstedt - Wolmirstedt 491 [OPP] [D8]	742.32	29.76%	25.42%
[D2-D8] Helmstedt - Wolmirstedt 492 [OPP] [D8]	742.32	29.76%	25.42%
[D8-D8] Baerwalde - Schmoelln 552 [DIR]	742.00	29.75%	28.88%
[D8-D8] Baerwalde - Schmoelin 551 [DIR]	742.00	29.75%	28.88%



TSO	Average maximum AMR per TSO
AT	70.26
BE	296.40
CZ	275.93
D2	774.50
D4	376.79
D7	631.06
D8	967.98
FR	883.61
HR	26.68
HU	188.12

TSO	Average maximum AMR per TSO
NL	527.36
PL	184.43
RO	128.52
SI	53.93
SK	194.83



#### **KPI 3: Share of MTUs with intervention per TSO**



Total BDs

30

Total MTUs

720

MTUs without IVA

276

Share of distinct MTUs without IVA

38.3%

MTUs with IVA

444


61.7%

Share of distinct

MTUs with IVA


Share of distinct MTUs **Distinct MTUs** TSO with IVA with IVA ΑT 0.83% 0.14% ΒE CZ 0.56% D2 0.69% D4 0.56% 2.92% 21 D7 6 D8 0.83% 155 FR 21.53% 21.53% HR 155 HU 86 11.94%

TSO	Share of distinct MTUs with IVA	Distinct MTUs with IVA
NL	4.58%	33
PL	0.42%	3
RO	21.81%	157
SI	1.94%	14
SK	10.97%	79




#### KPI 4a: Average IVA applied for each CNE affected by TSO intervention






#### KPI 4b: Average relative IVA applied for each CNE affected by TSO intervention





































#### **KPI 6a: Highest virtual margins at market balance for CORE TSOs**

















































































### **KPI 7: Non-Core exchanges AC delta flow**





### **KPI 7: Non-Core exchanges DC delta flow**






#### **KPI 8: NRAO – Applied Remedial Action**



In the following plots, the relative time share relates to the hours labeled 'NRAO Ran and Applied RAs'.


Total MTUs: 720 hours

Category	Hours (%)
NRAO ran and did not apply RAs	546 hours (75.8%)
NRAO ran and applied RAs	174 hours (24.2%)
Spanning before and @initial	0 hours (0%)
DFP before and @initial	0 hours (0%)
NRAO did not run	0 hours (0%)




### **KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode**





# KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode Relative Time Share of Applied PSTs in Preventive Mode






# **KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode Relative Time Share of Applied PSTs in Curative Mode**





# **KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode**Relative Time Share of Applied Topological RAs in Preventive Mode





# KPI 8: Relative Time Share of Applied RAs, by TSO, Type and Mode Relative Time Share of Applied Topological RAs in Curative Mode






#### **KPI 9: Most limiting CNEC per TSO (NRAO)**



The graph below shows the distribution of CNECs which are the most limiting from NRAO perspective, these are the CNECs with lowest relative RAM per MTU



As expected, there is redistributing of the most limiting CNECs. This is because the application of Remedial Actions does not eliminate flows but re-routes, reducing the flows on some limiting CNECs and increasing the load on others, which at the end impacts also the RAM values.


#### KPI 10: Average variation of relative RAM before and after NRAO



The graph shows average values of relative RAM before and after NRAO, per TSO on the most limiting CNECs from NRAO perspective. Selected CNECs before RAO are the same as after RAO, and average computed for MTUs when was used further in the process.

- Most limiting element from NRAO perspective is the one which has the lowest relative RAM per MTU
- To determine value of relative RAM, the following formula was used

$$RAM_{rel} = \left\{ egin{align*} rac{RAM_{nrao}}{\sum_{(A,B) \in neighbouring\ Core\ bidding\ zones\ pairs} |PTDF_{A 
ightarrow B,nrao}|},\ if\ RAM_{nrao} \geq 0 \ \ RAM_{nrao},\ if\ RAM_{nrao} < 0 \end{array} 
ight.$$



#### **KPI 11: Most often presolved CNEs (top 20)**



CNE &	Distinct hours CNE was presolved	Count of presolved CNECs	Avg RAM/Fmax	Min RAM/Fmax	Max RAM/Fmax	Max z2zPTDF	Max sum z2zPTDF
[AT-HU] Zurndorf - Gyoer 439B [DIR] [AT]	720	2090	82.51%	18.47%	118.04%	0.4032	1.6877
[HR-SI] 220kV Pehlin - Divaca [OPP] [HR]	720	1424	109.99%	80.48%	151.07%	0.2136	0.4998
[HR-SI] 220kV Pehlin - Divaca [DIR] [HR]	720	819	63.37%	32.35%	90.11%	0.2136	0.4998
[AT-CZ] Duernrohr 1 - Slavetice 437 [OPP] [AT]	720	720	67.92%	42.75%	87.61%	0.287	1.1547
[SI-HU] 400 kV Cirkovce - Hevitz [DIR] [SI]	720	1437	99.36%	72.32%	138.23%	0.2391	1.1789
[HU-HU] Gonyu - Gyor [DIR]	720	1431	82.80%	58.08%	124.39%	0.3689	1.5554
[CZ-SK] Nosovice - Varin [OPP] [CZ]	719	933	98.90%	77.68%	121.31%	0.3933	1.5044
[CZ-SK] Nosovice - Varin [DIR] [CZ]	719	1072	80.96%	59.06%	102.35%	0.3933	1.5044
[AT-AT] Westtirol 1 - Westtirol 2 WTRHU41 [OPP]	718	1196	52.88%	19.80%	126.60%	0.2269	1.0285
[AT-SI] Obersielach - Podlog 247 [DIR] [AT]	718	1702	71.23%	22.16%	128.16%	0.1853	0.5841
[CZ-SK] Nosovice - Varin [OPP] [SK]	718	1033	97.38%	77.85%	115.77%	0.3674	1.3094
[HU-HU] Gonyu - Gyor [OPP]	717	1235	98.24%	65.30%	137.01%	0.3689	1.5553
[SI-HU] 400 kV Cirkovce - Hevitz [OPP] [SI]	712	1467	80.82%	49.50%	107.66%	0.2391	1.1789
[NL-D7] Maasbracht - Oberzier SELFK WS [DIR] [D7]	708	917	81.10%	20.03%	128.46%	0.2772	0.6042
[PL-PL] Krosno Iskrzynia - Rzeszow [OPP]	705	705	67.73%	49.96%	90.88%	0.3054	1.0384
[D8-D8] Roehrsdorf - Roehrsdorf PST442 [DIR]	703	703	58.46%	31.53%	115.23%	0.2818	1.1971
[AT-SI] Obersielach - Podlog 247 [OPP] [AT]	696	1434	104.43%	49.74%	160.95%	0.1853	0.5841
[D8-PL] Mikulowa PST1 [DIR] [PL]	695	695	58.46%	48.11%	83.18%	0.4215	1.4921
[SK-SK] Gabcikovo - P.Biskupice [DIR]	679	679	84.20%	70.50%	99.50%	0.3701	1.2888
[HR-HU] 400kV Ernestinovo - Pecs 1 [OPP] [HR]	672	672	76.54%	60.98%	89.25%	0.2779	0.8559

Note 1: The shown z2zPTDF values do not correspond to the maximum zone-to-zone PTDFs according to equation 5 of the Day-ahead CCM and hence are not the ones used for the CNEC Selection. The z2zPTDFs are calculated only between neighbouring BZs. See KPI reading guide on JAO.

Note 2: RAM for Core exchanges can be higher than 100% due to the relieving effect of Fuaf: RAM\_Core = CEP\_target - Fuaf. So if Fuaf is very negative you can get above 100%.

#### **KPI 12: Most limiting CNEs (top 20)**



CNE &	Distinct hours CNE has shadow price	Count of hours CNECs have shadow price	Max shadow price [€/MW]	Avg RAM/Fmax 💂	Min RAM/Fmax 🗍	Max RAM/Fmax ♣	Max z2zPTDF ↓
[BE-FR] Achene - Lonny 380.19 [OPP] [BE]	343	343	277.52	76.65%	41.08%	98.57%	0.3958
[FR-FR] Creys - Saint-Vulbas 1 [OPP]	271	271	635.36	20.32%	19.97%	30.26%	0.1705
[FR-FR] Creys - Saint-Vulbas 2 [OPP]	264	264	889.78	21.00%	19.97%	35.49%	0.1668
[AT-HU] Zurndorf - Gyoer 439B [DIR] [AT]	110	111	445.03	74.19%	18.47%	100.87%	0.3798
[FR-D7] Vigy - Ensdorf VIGY2 S [DIR] [D7]	75	77	439.5	27.49%	19.90%	62.37%	0.2651
[CZ-SK] Nosovice - Varin [DIR] [CZ]	74	74	251.78	73.19%	59.48%	87.84%	0.3933
[AT-AT] Strass - Thaur 273B [DIR]	70	70	1940.37	38.03%	19.60%	99.08%	0.1346
[AT-D2] St. Peter 2 - Pleinting 258 [OPP] [AT]	69	70	402.81	52.78%	24.14%	85.69%	0.1545
[NL-NL] MEE DRT2 [DIR] [NL]	66	66	391.77	28.81%	19.96%	80.13%	0.2729
[AT-SI] Obersielach - Podlog 247 [DIR] [AT]	65	67	582.56	60.30%	27.37%	113.42%	0.1769
[D8-PL] Mikulowa PST1 [DIR] [PL]	53	53	292.41	54.82%	49.39%	61.14%	0.4097
[NL-NL] Krimpen a/d IJssel-Geertruidenberg 380 W [DIR]	47	47	160.89	51.01%	19.97%	104.44%	0.5332
[SK-HU] Levice - God [DIR] [HU]	45	45	824.86	56.28%	32.03%	70.92%	0.2402
[RO-RO] TR Rosiori 400/220 1 [DIR]	42	42	1414.29	49.66%	39.38%	67.71%	0.1072
[RO-RO] PST Arad 400/220 3 [DIR]	35	35	965.92	78.41%	64.75%	98.75%	0.1301
[AT-D2] St. Peter 2 - Pleinting 258 [DIR] [AT]	28	28	131.14	64.23%	38.55%	86.96%	0.157
[PL-PL] Krosno Iskrzynia - Rzeszow [OPP]	28	28	113.6	60.80%	53.86%	81.74%	0.2936
[BE-BE] Achene - Gramme 380.10 [DIR]	27	27	115.47	88.91%	80.49%	100.12%	0.3962
[D7-FR] Ensdorf - Vigy VIGY2 S [OPP] [FR]	22	22	267.61	28.81%	19.96%	41.35%	0.2582
[BE-FR] Achene - Lonny 380.19 [DIR] [BE]	21	21	227.65	94.20%	77.65%	107.24%	0.3873

Note 1: The RAM values (expressed as % of Fmax) should not be interpreted as "the capacities offered by the Core TSOs to the market coupling". Indeed, since the introduction of Ext LTA inclusion Euphemia performs an optimization where it takes a portion of the FB domain and a portion of the LTA domain to maximize welfare. The RAM value shown in this KPI report correspond to the "portion of the FB domain" resulting from this optimization Example:

- RAM = 500MW
- Portion of FB Domain = 40%
- RAM offered by Core TSOs = 500MW/0.4 = 1250MW

#### **KPI 13: Allocation Constraints - Poland**



	# MTUs
AC was limiting MC	161
AC < 0 MW	41
AC = 0 MW	117
AC > 0 MW	3

	PL AC Import [MW]	PL AC Export [MW]
Avg.	-1185.37	6414.31
Min.	-9628.00	0.00
Max.	0.00	16468.00

